





Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: 32 (0)2 264 03 60
Fax: 32 (0)2 268 89 58
http://www.apragaz.com
info@apragaz.com



NOTIFIED BODY EU TYPE EXAMINATION CERTIFICATE		Certificate N° 17/IT/4208-0-Rev0
In accordance with module B of the Marine Equipment Directive 2014/90/EU as amended		
Manufacturer	Name	ANAF FIRE PROTECTION S.P.A.
	Address	Via del Commercio 4 I-27020 Torre d'Isola (Pavia) ITALY
Concerned Equipment : Portable CO2 Fire Extinguishers		
Type : 2kg / 5kg Carbone Dioxide « CO2 » ref. CS2-AB / CS5-AB and CS2-AM / CS5-AM according to technical design ref. 50.754B.F000.00; 50.754M.F000.00; 50.757B.F000.00 and 50.757M.F000.00		
Capacities : 2-5kg CO ₂ (3l - 7,5l)		
Set pressure : 169.3 bar / 174 bar (60°C)		
Test pressure : PT 212 bar / 250 bar		
Service temperature range : min. -30°C / max. +60°C		
<p>The manufacturer is allowed to affix the Mark  to the approved equipment under the conditions described in article 10 of the Directive and only if the requirements stated in module D are fully met.</p> <p>The approval is valid until 02/07/2022.</p>		
APRAGAZ, acting within the scope of its notification for the purpose of the European Council Directive 2014/90/EU, certifies that the design of these pressure vessels conform to the relevant requirements of the pertinent EN3 standards in force and the Pressure Equipment Directive 2014/90/EU on basis of the documentation and samples supplied for review and approval.		
Date : 03/07/2017	Name : Ch. Leplat	Position General Manager
Notified body identification number :	0029	Signature 
Notified body stamp :	APRAGAZ Belgium Inspecting Authority	
Notified body reference :	P4434/006	